



SECTION THROUGH
SHAFT EXTENSION.
(SCALE 1:3).

NOTE:
TERMINAL BOX CAN BE MOUNTED (LEFT OR RIGHT) BY REFITTING FEET AND LIFTING LUGS 90° IN APPROPRIATE DIRECTIONS. CABLE ENTRY CAN BE SUPPLIED IN ANY ONE OF FOUR POSITIONS AT 90° INTERVALS.

CUSTOMER		
ORDER No.		
SERIAL No.		
FRAME SIZE		
Kw		R.P.M.
Hz		PHASE 3
VOLTS		POLES
BRGS.	D.E	N.D.E
MOTOR NETT. WT.		Kg.
INSULATION CLASS		
TEMPERATURE RISE °C		
DESIGN AMBIENT TEMPERATURE °C		
HEATER WATTS & VOLTS (IF FITTED)		
- WATTS, - VOLTS		

REMARKS

EEx de IIB
BASEEFA CERTIFICATE
No. Ex98E1118X.

OR

EEx de IIC
BASEEFA CERTIFICATE
No. Ex98E1119X.

ALL DIMENSIONS IN MILLIMETRES



NOTE:
2.5 ENDPLAY WILL BE PROVIDED FOR ENDTHRUST PROTECTION WHEN CUSTOMERS NOTIFY US OF THEIR INTENTION TO USE RIGID COUPLINGS AND DRIVEN MACHINES WITHOUT ENDPLAY.

OUTLINE DIMENSIONS OF STANDARD FOOT MOUNTED METRIC A.C MOTOR TO BS4999 PART 141. EEx de TO EN50014/18/19. TOTALLY ENCLOSED FAN VENTILATED. FRAME SIZE: W-EF225M (4 POLE UP).

SCALE	1:6	DATE
DRAWN	M.E	4.1.99
CHECKED	M.B.C	4.1.99
APPROVED	M.B.C	4.1.99

DRG. No. M70069

REVISION: DATE