


SECTION THROUGH
SHAFT EXTENSION
(SCALE 1:2)

NOTE: -
TERMINAL BOX CAN BE SIDE MOUNTED
(LEFT OR RIGHT) BY REFITTING FEET
90° IN APPROPRIATE DIRECTION.
CABLE ENTRY CAN BE SUPPLIED IN
ANY ONE OF FOUR POSITIONS AT
90° INTERVALS.

CUSTOMER		
ORDER No.		
SERIAL No.		
FRAME SIZE		
kw	RPM.	
Hz	PHASE 3	
VOLTS	POLES	
BRGS.	DE.	NDE.
MOTOR NETT. WT.		Kg.
INSULATION CLASS		
TEMPERATURE RISE °C		
DESIGN AMBIENT TEMPERATURE °C		
HEATER WATTS & VOLTS		
WATTS,		VOLTS


REMARKS



Brook Invensys Crompton
PRELIMINARY

Large Industrial Motors
Guiseley, LEEDS LS20 9NZ.

ALL DIMENSIONS IN MILLIMETRES



FIRST ANGLE
PROJECTION

BROOK CROMPTON

NOTE !
2.5 ENDPLAY WILL BE PROVIDED FOR ENDTHRUST
PROTECTION WHEN CUSTOMERS NOTIFY US OF THEIR
INTENTION TO USE RIGID COUPLINGS AND DRIVEN
MACHINES WITHOUT ENDPLAY.

OUTLINE DIMENSIONS OF STD. FOOT/FLANGE MOUNTED METRIC A. C. MOTOR
TO BS. 4999 PART 141. TOTALLY ENCLOSED FAN VENTILATED.
FITTED WITH TOP MOUNTED TERMINAL BOX
FRAME SIZE :- W-DF225M-H (4 POLE UP)

SCALE	1:6	DATE
DRAWN	BJT	31.1.92
CHECKED	B.J.T.	31.1.92
APPROVED	I.J.W.	31.1.92

DRG. No.	M8664		
REVISION:	A	DATE	BJT 15.4.93